

DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

June 17, 2015

WATER RIGHT INCORPORATED KURT GRUETT 1900 PROSPECT COURT APPLETON WI 54914

Re: Description: WATER TREATMENT DEVICE - SOFTENER/CATION EXCHANGE

Manufacturer: WATER RIGHT INCORPORATED Product Name: AS SERIES (trans id 2561906)

Model Number(s): AS-844-T, AS-844-M, AS-844-ME, AS-1044-T, AS-1044-M, AS-1044-ME, AS-1054-T,

AS-1054-M, AS-1054-ME, AS-1354-T, AS-1354-M AND AS-1354-ME (POE)

Product File No: 20150161

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2020.

This approval supersedes the approval issued on July 19, 2010 under product file number 20100256.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those
 contaminants and/or substances as specified in this approval letter when the product is installed and maintained
 in strict accordance with the manufacturer's published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- These cation exchange water softeners shall be sized, installed, programmed and maintained such that wastewater volumes, total dissolved solids and chloride discharges are minimized.
- These devices generate and discharge significant concentrations of free chlorine during each regeneration.

This fact should be considered as part of an overall program of inspection and maintenance for private on-site waste treatment systems (e.g. septic tank).

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

SBD-10564-E (N.10/97) File Ref: 15016101.DOC

Water Right Incorporated June 17, 2015

Page 2 of 2

Product File No.: 20150161

WATER SOFTENING CAPABILITIES PRODUCT FILE NUMBER 20150161 TABLE 1 OF 1

Model Numbers		Capacity*						Flow Rate vs.
AS Series		Rating 1		Rating 2		Rating 3		Pressure Loss
Metered	Fully Automatic	Grains	Pounds	Grains	Pounds	Grains	Pounds	gpm @ psig
AS-844-M	AS-844-T	11,800	3.2	16,100	6.1	18,900	9.3	10.0 @ 15
AS-1044-M	AS-1044-T	22,000	6.1	26,100	9.3	31,700	15.9	13.0 @ 15
AS-1054-M	AS-1054-T	37,500	9.3	47,100	15.9	55,300	23.8	11.0 @ 15
AS-1354-M	AS-1354-T	62,500	15.3	78,500	26.3	88,800	39.7	14.0 @ 15
AS-844-ME	-	11,800	3.2	16,100	6.1	18,900	9.3	10.0 @ 15
AS-1044-ME	-	22,000	6.1	26,100	9.3	31,700	15.9	13.0 @ 15
AS-1054-ME	-	37,500	9.3	47,100	15.9	55,300	23.8	11.0 @ 15
AS-1354-ME	-	62,500	15.3	78,500	26.3	88,800	39.7	14.0 @ 15

^{*} The softener capacity rating is based on grains of hardness, due to calcium and magnesium cations, removed (as calcium carbonate) while producing soft water between successive regenerations and is related to the pounds of salt required for each regeneration. The tests run to verify the data for table 1 of 1 were conducted via column studies and scaling calculations by Baumbach Lab, Appleton WI.

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Depart of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail